



6/21/2020

Work Order: 20F0762
Project: EID

Aqua Environmental Services
Attn: Larry Hall
89 W. Monarch
Bountiful, UT 84010

Client Service Contact: 801.262.7299

The analyses presented on this report were performed in accordance with the National Environmental Laboratory Accreditation Program (NELAP) unless noted in the comments, flags, or case narrative. If the report is to be used for regulatory compliance, it should be presented in its entirety, and not be altered.



Approved By:

Dave Gayer, Laboratory Director



Certificate of Analysis

Lab Sample No.: 20F0762-01

Name: Aqua Environmental Services	Sample Date: 6/3/2020 7:00 AM
Sample Site: 75 Silver Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.177	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0016	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-02

Name: Aqua Environmental Services	Sample Date: 6/3/2020 6:30 AM
Sample Site: 5430 E Pioneer Fork Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.187	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0028	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-03

Name: Aqua Environmental Services	Sample Date: 6/3/2020 7:30 AM
Sample Site: 46 Smokey Lane	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.147	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0032	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-04

Name: Aqua Environmental Services	Sample Date: 6/3/2020 6:55 AM
Sample Site: 124 Young Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.179	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0067	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-05

Name: Aqua Environmental Services	Sample Date: 6/4/2020 6:30 AM
Sample Site: 135 Young Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.143	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0010	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-06

Name: Aqua Environmental Services	Sample Date: 6/2/2020 5:00 AM
Sample Site: 160 Young Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.140	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0022	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-07

Name: Aqua Environmental Services	Sample Date: 6/3/2020 6:27 AM
Sample Site: 159 Young Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.170	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0018	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-08

Name: Aqua Environmental Services	Sample Date: 6/2/2020 7:00 AM
Sample Site: 345 Middle Oak Lane	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.231	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0045	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-09

Name: Aqua Environmental Services	Sample Date: 6/4/2020 7:49 AM
Sample Site: 161 Young Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.114	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0012	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-10

Name: Aqua Environmental Services	Sample Date: 6/3/2020 6:20 AM
Sample Site: 45 N Silver Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.116	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0009	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-11

Name: Aqua Environmental Services	Sample Date: 6/3/2020 6:20 AM
Sample Site: 5199 E Silver Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.140	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0010	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-12

Name: Aqua Environmental Services	Sample Date: 6/8/2020 6:30 AM
Sample Site: 142 N Young Oak Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	18.2	1.3	0.0200	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0332	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-13

Name: Aqua Environmental Services	Sample Date: 6/2/2020 10:00 AM
Sample Site: 330 Middle Oak Lane	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.0980	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	ND	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-14

Name: Aqua Environmental Services	Sample Date: 6/3/2020 10:20 AM
Sample Site: 1121 N Burnt Fork Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.124	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0048	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-15

Name: Aqua Environmental Services	Sample Date: 6/2/2020 7:10 AM
Sample Site: 1112 N Burnt Fork Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.102	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0007	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-16

Name: Aqua Environmental Services	Sample Date: 6/3/2020 7:30 AM
Sample Site: 1146 N Burnt Fork Road	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	1.43	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0197	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-17

Name: Aqua Environmental Services	Sample Date: 6/3/2020 7:20 AM
Sample Site: 1058 N Killyons Lane	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	1.78	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0024	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-18

Name: Aqua Environmental Services	Sample Date: 6/8/2020 8:40 AM
Sample Site: 1221 N Killyons Lane	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.276	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0080	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Lab Sample No.: 20F0762-19

Name: Aqua Environmental Services	Sample Date: 6/8/2020 5:58 AM
Sample Site: 1207 N Killyons Lane	Receipt Date: 6/11/2020 11:21 AM
Comments:	Sampler: Homeowners
Sample Matrix: Drinking Water	Project: EID
PO Number:	System No.: UTAH18143
Source Code: DS001	Sample Point: DS001
	Report to State: Y

Parameter	Sample Result	EPA Max Contaminant Level (MCL)	Minimum Reporting Limit	Units	Analytical Method	Preparation Date/Time	Analysis Date/Time	Flag
Metals								
Copper, Total	0.0896	1.3	0.0010	mg/L	EPA 200.8	06/12/2020	06/12/2020	
Lead, Total	0.0013	0.015	0.0005	mg/L	EPA 200.8	06/12/2020	06/12/2020	



Certificate of Analysis

Report Footnotes

Abbreviations

ND = Not detected at the corresponding Minimum Reporting Limit.

1 mg/L = one milligram per liter or 1 mg/Kg = one milligram per kilogram = 1 part per million.

1 ug/L = one microgram per liter or 1 ug/Kg = one microgram per kilogram = 1 part per billion.

1 ng/L = one nanogram per liter or 1 ng/Kg = one nanogram per kilogram = 1 part per trillion.

Data Comparisons

Values reported in **RED** exceed Primary Drinking Water standards.

Values reported in **BLUE** exceed Secondary Drinking Water standards.

BLANK values in the MCL column indicate no standard.

CHEMTECH - FORD ANALYTICAL LABORATORY

CHAIN OF CUSTODY

COMPANY: Aqua Environmental Services Inc
 ADDRESS: 89 W Monarch Dr
 CITY/STATE/ZIP: Bountiful UT 84010
 PHONE #: 801-209-6382 FAX: _____
 CONTACT: Larry Hall PROJECT: EID
 EMAIL: larryh@aquaeviron.com

BILLING ADDRESS: SAME
 BILLING CITY/STATE/ZIP: _____
 PURCHASE ORDER: _____



TURNAROUND TIME REQUIRED: _____
 * Expedited turnaround subject to additional charge

* Expedited turnaround subject to additional charge

State System Number
 UTAH18143

Send to State
 Yes No

TESTS REQUESTED												Bacteria			LAB FAIL Ref #
												R = Routine I = Investigative TR = Trigger Source RP = Repeat			
												Total Coliform + E. coli (Present/Absent)	Total Coliform + E. coli (Enumerated)	HPC (Plate Count)	

Lab Use Only	CLIENT SAMPLE INFORMATION					
	LOCATION	DATE	TIME	FACILITY ID (source code)	POINT CODE (DBP)	Field: Residual Chlorine
20F0702	1. 75 Silver Oak Road	6/3/20	7:00 AM	LC001		
01	2. 5430 E Pioneer Fork Road	6/3/20	6:30 AM	LC003		
02	3. 46 Smokey Lane	6/3/20	7:30	LC004		
03	4. 124 Young Oak Road	6/3/20	6:55 AM	LC005		
04	5. 135 Young Oak Road	6/4/20	6:30 AM	LC006		
05	6. 160 Young Oak Road	6/2/20	5 AM	LC007		
06	7. 159 Young Oak Road	6/3/20	6:27 AM	LC008		
07	8. 345 Middle Oak Lane	6/2/20	7:00 AM	LC009		
08	9. 161 Young Oak Road	6/4/20	7:49 AM	LC010		
09	10. 45 N Silver Oak Road	6/3/20	6:20 AM	LC011		

ON ICE NOT ON ICE Temp (C°): 19.3

Samples received outside the EPA recommended temperature range of 0-6 C° may be rejected.

Sampled by: [print] Residents	Sampled by: [signature]		
Special Instructions:			
Relinquished by: [signature]	Date/Time: 6-10-20 19:00	Received by: [signature]	Date/Time: 6-10-20 19:00
Relinquished by: [signature]	Date/Time: 6-11-20 11:21	Received by: [signature]	Date/Time: 6-11-20 11:21
Relinquished by: [signature]	Date/Time:	Received by: [signature]	Date/Time:

CHEMTECH-FORD
 9632 South 500 West
 Sandy, UT 84070

801.262.7299 PHONE
 866.792.0093 FAX
 www.ChemtechFord.com

Payment Terms are net 30 days OAC. 1.5% interest charge per month (18% per annum).
 Client agrees to pay collection costs and attorney's fees.

Handwritten initials

~~1270E890380800187~~

CHEMTECH - FORD ANALYTICAL LABORATORY

CHAIN OF CUSTODY

COMPANY: Aqua Environmental Services Inc
 ADDRESS: 89 W Monarch Dr
 CITY/STATE/ZIP: Bountiful UT 84010
 PHONE #: 801-209-6382 FAX: _____
 CONTACT: Larry Hall PROJECT: EID
 EMAIL: larryh@aquaeviron.com

BILLING ADDRESS: SAME
 BILLING CITY/STATE/ZIP: _____
 PURCHASE ORDER: _____



* Expedited turnaround subject to additional charge

TURNAROUND TIME REQUIRED: _____
 * Expedited turnaround subject to additional charge

State System Number
 UTAH18143

Send to State
 Yes No

TESTS REQUESTED												Bacteria						
												Total Coliform + E. coli (Present/Absent)	Total Coliform + E. coli (Enumerated)	HPC (Plate Count)	R = Routine	I = Investigative	TR = Trigger Source	RP = Repeat
															REPEAT			
															OR = Original Location	UP = Upstream	DN = Downstream	

** Per bottle*

Lab Use Only	CLIENT SAMPLE INFORMATION						
2050742	LOCATION	DATE	TIME	FACILITY ID (source code)	POINT CODE (DBP)	Field: Residual Chlorine	Pb & Cu
11	1. 5199 E Silver Oak Road	6/8/20	6:20	LC012			
12	2. 142 N Young Oak Road	6/8/20	6:30 AM	LC013			
13	3. 330 Middle Oak Lane	6/2/20	10 AM	LC014			
14	4. 1121 N Burnt Fork Road	6/3/20	10:20 AM	LC015			
15	5. 1112 N Burnt Fork Road	6/2/20	7:10 AM	LC016			
16	6. 1146 N Burnt Fork Road	6/3/20	7:30 AM	LC017			
17	7. 1058 N Killyons Lane	6/3/20	7:20 AM	LC018			
18	8. 1221 N Killyons Lane	6/8/20	8:40	LC020			
19	9. 1207 N Killyons Lane	6/8/20	5:58 AM	LC021			
	10. 45 N Silver Oak Road						

Sampled by: [print] Residents Sampled by: [signature]

Special Instructions: **ON ICE** **NOT ON ICE** Temp (C°): 19.3

Samples received outside the EPA recommended temperature range of 0-6 C° may be rejected.

Relinquished by: [signature]	Date/Time: 6-10-20 19:00	Received by: [signature]	Date/Time: 6-10-20 19:00
Relinquished by: [signature]	Date/Time: 6-11-20 11:21	Received by: [signature]	Date/Time: 6-11-20 11:21
Relinquished by: [signature]	Date/Time:	Received by: [signature]	Date/Time:

CHEMTECH-FORD
 9632 South 500 West
 Sandy, UT 84070

801.262.7299 PHONE
 866.792.0093 FAX
 www.ChemtechFord.com

Payment Terms are net 30 days OAC. 1.5% interest charge per month (18% per annum).
 Client agrees to pay collection costs and attorney's fees.

12700 E 89038080 0187

Work Order # 20F07102

CHEMTECH FORD LABORATORIES

Sample Receipt



CHEMTECH-FORD
LABORATORIES

Delivery Method:

- UPS
- USPS
- FedEx
- Chemtech Courier
- Walk-in
- Customer Courier

Receiving Temperature 14.3°C

Sample #	Container	Chemtech Lot # or Preservative	Number of Subsamples	Preserved by Client/Third Party	Preserved in Receiving Laboratory	Preserved in Field by Client	Misc Volume (oz/ml)	Comments
01-19	AH					X		

Sample Condition
(check if yes)

- Custody Seals
- Containers Intact
- COC can be matched to bottles
- Received on Ice
- Correct Container(s)
- Sufficient Sample Volume
- Headspace Present (VOC)
- Temperature Blank
- Received within Holding Time

Plastic Containers

- A- Plastic Unpreserved
- B- Miscellaneous Plastic
- C- Cyanide Qt (NaOH)
- E- Coliform/Ecoli/HPC
- F- Sulfide Qt (Zn Acetate)
- L- Mercury 1631
- M- Metals Pint (HNO3)
- N- Nutrient Pint (H2SO4)
- R- Radiological (HNO3)
- S- Sludge Cups/Tubs
- Q- Plastic Bag

Glass Containers

- D- 625 (Na2S2O3)
- G- Glass Unpreserved
- H- HAAs (NH4Cl)
- J- 508/515/525 (Na2SO3)
- K- 515.3 Herbicides
- O- Oil & Grease (HCl)
- P- Phenols (H2SO4)
- T- TOC/TOX (H3PO4)
- U- 531 (MCAA, Na2S2O3)
- V- 524/THMs (Ascorbic Acid)
- W- 8260 VOC (1:1 HCl)
- X- Vial Unpreserved
- Y- 624/504 (Na2S2O3)
- Z- Miscellaneous Glass